



Number	110319/01	Replaces	--
Issued	15/04/2023	Scope	AR 214
Contract number	Q22/01	Page	1-2

Product Certificate

Gas distribution valves

Based on pre-certification tests as well as periodic inspections by Kiwa Nederland B.V., the products referred to in this certificate and marked with the GASTEC QA mark, supplied by

Wouter Witzel Eurovalve B.V.

may, on delivery, be relied upon to comply with the GASTEC QA Approval Requirements 214 "Fitness for admixtures up to and including 100% hydrogen gas" dated September 2022.

Ron Scheepers
Kiwa

This certificate is issued by Kiwa Nederland B.V. in conjunction with the KIWA regulations for Certification 2017.

This certificate consists of 2 pages.
Publication of the certificate is allowed.

Kiwa Nederland B.V.
Sir. Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands
Tel.+31 88 998 4400
NL.kiwa.info@kiwa.com
www.kiwa.nl

supplier
Wouter Witzel EuroValve BV
Industrieterrein de Pol 12
7581 CZ Losser
The Netherlands

www.wouterwitzel.nl

T +31 53 536 95 36
E info@wouterwitzel.nl



Number	110319/01	Replaces	--
Issued	15/04/2023	Scope	AR 214
Contract number	Q22/01	Page	2-2

Gas distribution valves

PRODUCT SPECIFICATION

Gas distribution valves:

Type EVS/ EVTLS/ EVFS/ EVFL; DN 50, 65, 80, 100, 125, 150, 200, 250, 300, 350, 400, 450, 500, 550, 600, 650, 700, 750, 800, 900 and 1000

Type EVCS/ EVBS/ DN 50, 65, 80, 100, 125, 150, 200, 250 and 300

Type EVMS DN 350, 400, 450, 500, 550 and 600

Type EVML DN 350, 400, 450, 500, 550, 600, 650, 700, 750 and 800

Type EVUS valves DN600, 650, 700, 750, 800, 900 and 1000

APPLICATION AND USE

The products are intended to be applied as gas distribution and installation materials for natural gas with an admixture of 20% hydrogen gas and pure hydrogen gas. The maximum operating pressure (MOP) and operating temperature are specified in the approval requirement for the product for GASTEC QA certification.

MARKING

- GASTEC QA, GASTEC QA Logo or trademark.
 - Manufacturers' name or trademark
 - PN
 - Direction of flow (if necessary)
 - Nominal size DN
 - Traceability identification
 - The words 'Bestand tegen waterstofgas' and 'Hydrogen ready'
-

RECOMMENDATIONS FOR END USERS

Check at the time of delivery whether:

- the producer has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport.

Consult the producer's processing guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting Kiwa Nederland B.V. or the Kiwa website.

If you should reject a product on the basis of the above, please contact the supplier and, if necessary, Kiwa Nederland B.V.
